



Combustion of Hydrogen rich fuels in process heaters

Influence on thermal performance, emissions, and safety aspects

Stefano Mania

Senior Heat Transfer Engineer
Shell Global Solutions International BV

26 May 2023

Definitions & cautionary note

Cautionary Note

The companies in which Shell plc directly and indirectly owns investments are separate legal entities. In this presentation “Shell”, “Shell Group” and “Group” are sometimes used for convenience where references are made to Shell plc and its subsidiaries in general. Likewise, the words “we”, “us” and “our” are also used to refer to Shell plc and its subsidiaries in general or to those who work for them. These terms are also used where no useful purpose is served by identifying the particular entity or entities. “Subsidiaries”, “Shell subsidiaries” and “Shell companies” as used in this presentation refer to entities over which Shell plc either directly or indirectly has control. Entities and unincorporated arrangements over which Shell has joint control are generally referred to as “joint ventures” and “joint operations”, respectively. “Joint ventures” and “joint operations” are collectively referred to as “joint arrangements”. Entities over which Shell has significant influence but neither control nor joint control are referred to as “associates”. The term “Shell interest” is used for convenience to indicate the direct and/or indirect ownership interest held by Shell in an entity or unincorporated joint arrangement, after exclusion of all third-party interest.

Forward-Looking Statements

This presentation contains forward-looking statements (within the meaning of the U.S. Private Securities Litigation Reform Act of 1995) concerning the financial condition, results of operations and businesses of Shell. All statements other than statements of historical fact are, or may be deemed to be, forward-looking statements. Forward-looking statements are statements of future expectations that are based on management’s current expectations and assumptions and involve known and unknown risks and uncertainties that could cause actual results, performance or events to differ materially from those expressed or implied in these statements. Forward-looking statements include, among other things, statements concerning the potential exposure of Shell to market risks and statements expressing management’s expectations, beliefs, estimates, forecasts, projections and assumptions. These forward-looking statements are identified by their use of terms and phrases such as “aim”, “ambition”, “anticipate”, “believe”, “could”, “estimate”, “expect”, “goals”, “intend”, “may”, “milestones”, “objectives”, “outlook”, “plan”, “probably”, “project”, “risks”, “schedule”, “seek”, “should”, “target”, “will” and similar terms and phrases. There are a number of factors that could affect the future operations of Shell and could cause those results to differ materially from those expressed in the forward-looking statements included in this presentation, including (without limitation): (a) price fluctuations in crude oil and natural gas; (b) changes in demand for Shell’s products; (c) currency fluctuations; (d) drilling and production results; (e) reserves estimates; (f) loss of market share and industry competition; (g) environmental and physical risks; (h) risks associated with the identification of suitable potential acquisition properties and targets, and successful negotiation and completion of such transactions; (i) the risk of doing business in developing countries and countries subject to international sanctions; (j) legislative, judicial, fiscal and regulatory developments including regulatory measures addressing climate change; (k) economic and financial market conditions in various countries and regions; (l) political risks, including the risks of expropriation and renegotiation of the terms of contracts with governmental entities, delays or advancements in the approval of projects and delays in the reimbursement for shared costs; (m) risks associated with the impact of pandemics, such as the COVID-19 (coronavirus) outbreak; and (n) changes in trading conditions. No assurance is provided that future dividend payments will match or exceed previous dividend payments. All forward-looking statements contained in this presentation are expressly qualified in their entirety by the cautionary statements contained or referred to in this section. Readers should not place undue reliance on forward-looking statements. Additional risk factors that may affect future results are contained in Shell plc’s Form 20-F for the year ended December 31, 2021 (available at www.shell.com/investor and www.sec.gov). These risk factors also expressly qualify all forward-looking statements contained in this presentation and should be considered by the reader. Each forward-looking statement speaks only as of the date of this presentation, May 26, 2023. Neither Shell plc nor any of its subsidiaries undertake any obligation to publicly update or revise any forward-looking statement as a result of new information, future events or other information. In light of these risks, results could differ materially from those stated, implied or inferred from the forward-looking statements contained in this presentation.

Shell’s net carbon footprint

Also, in this presentation we may refer to Shell’s “Net Carbon Footprint” or “Net Carbon Intensity”, which include Shell’s carbon emissions from the production of our energy products, our suppliers’ carbon emissions in supplying energy for that production and our customers’ carbon emissions associated with their use of the energy products we sell. Shell only controls its own emissions. The use of the term Shell’s “Net Carbon Footprint” or “Net Carbon Intensity” are for convenience only and not intended to suggest these emissions are those of Shell plc or its subsidiaries.

Shell’s net-zero Emissions Target

Shell’s operating plan, outlook and budgets are forecasted for a ten-year period and are updated every year. They reflect the current economic environment and what we can reasonably expect to see over the next ten years. Accordingly, they reflect our Scope 1, Scope 2 and Net Carbon Footprint (NCF) targets over the next ten years. However, Shell’s operating plans cannot reflect our 2050 net-zero emissions target and 2035 NCF target, as these targets are currently outside our planning period. In the future, as society moves towards net-zero emissions, we expect Shell’s operating plans to reflect this movement. However, if society is not net zero in 2050, as of today, there would be significant risk that Shell may not meet this target.

Forward Looking Non-GAAP measures

This presentation may contain certain forward-looking non-GAAP measures. We are unable to provide a reconciliation of these forward-looking Non-GAAP measures to the most comparable GAAP financial measures because certain information needed to reconcile those Non-GAAP measures to the most comparable GAAP financial measures is dependent on future events some of which are outside the control of Shell, such as oil and gas prices, interest rates and exchange rates. Moreover, estimating such GAAP measures with the required precision necessary to provide a meaningful reconciliation is extremely difficult and could not be accomplished without unreasonable effort. Non-GAAP measures in respect of future periods which cannot be reconciled to the most comparable GAAP financial measure are calculated in a manner which is consistent with the accounting policies applied in Shell plc’s consolidated financial statements.

The contents of websites referred to in this presentation do not form part of this presentation.

We may have used certain terms, such as resources, in this presentation that the United States Securities and Exchange Commission (SEC) strictly prohibits us from including in our filings with the SEC. Investors are urged to consider closely the disclosure in our Form 20-F, File No 1-32575, available on the SEC website www.sec.gov.

About me





STEFANO MANIA
SENIOR HEAT TRANSFER ENGINEER
SHELL GLOBAL SOLUTIONS INTERNATIONAL B.V.
ENERGY TRANSITION CAMPUS AMSTERDAM



- 18 years in the industry
- Global SME for FD furnaces and Burners
- Technical focal point for safe H2 firing
- API/ISO reviewer/member, currently working in:
 - Development of the new standard ISO5133 “protective systems for Fired Heaters” replacing EN746
 - Support for revision of the new edition of API560, API561, API535 and API556
- I am Italian (born and raised in the sunny Sicily island)
- I have two boys aged 12 and 11 years old
- I play the piano and practice Jujitsu martial art since I was a little kid
- I have recently started a new hobby enjoying fishing with my sons

What is a Process Fired Heater

API560 defines a process heater as an equipment where heat, liberated by the combustion of fuels is transferred to fluids contained in tubular coils within an internally insulated enclosure.




What is a Process Burner

API535 defines a process burner as a device for the introduction of fuel and air into a heater at the desired velocities, turbulence, and air/fuel ratio to establish and maintain ignition and stable combustion.


Raw gas burners

Diffusive flame




Premix gas Burners

Straight flame



Radiant wall flame



Natural Draft / Forced Draft


Ref: John Zink Hamworthy Combustion Handbook

26 May 2023

How Fired Process Heaters work & Furnace Flooding Hazard

The process outlet temperature controls the amount of fuel fired by the burners.

Lower temperature calls for more fuel and vice versa.




How Fired Process Heaters work & Furnace Flooding Hazard

If flame instability occurs, part of fuel is not fired and does not transfer heat to the process coils anymore and the unburned fuel accumulates in the firebox.

This produces a drop of the process outlet temperature, and the control loop will respond by adding more fuel worsening the situation.

This process, the increasing accumulation of unburned fuel in the firebox is called "Furnace Flooding" (or Furnace Boggging).

If not properly controlled and safeguarded, a furnace flooding loop could escalate to serious process safety incidents including furnace explosion.



Furnace Control and Safeguard - Natural Draft Fired Heater




Figure 2—Natural Draft Fired Heater—Fuel Side

Instrumentation, Control, and Protective Systems for Gas Fired Heaters

API RECOMMENDED PRACTICE 556
SECOND EDITION, APRIL 2011

REAFFIRMED, APRIL 2019

energy **API**
AMERICAN PETROLEUM INSTITUTE




Figure 3—Natural Draft Fired Heater—Process Side

Flame dimension requirements and flame definition to prevent tubes overheating and flame impingement hazard

Fired Heaters for General Refinery Service

API STANDARD 560
FIFTH EDITION, FEBRUARY 2016



Burners for Fired Heaters in General Refinery Services

API RECOMMENDED PRACTICE 535
THIRD EDITION, MAY 2014



14 Burners and Auxiliary Equipment

14.1 Burners

14.1.1 Burner design, selection, spacing, location, installation, and operation shall ensure against flame impingement on tubes, tube supports, and flame exiting the radiant section of the heater throughout the entire operating range of the burners. The location and operation of burners shall ensure complete combustion within the radiant section of the heater.

14.1.2 Burners shall be designed in accordance with all local and national statutes and regulations.

14.1.3 For burner clearances, the data given in Table 15 shall be used for natural-draft burners and in Table 16 for forced-draft burners. The tables are based on low NO_x burners that are designed to reduce the formation of NO_x below levels generated during normal combustion in conventional burners.

14.1.4 In addition to 14.1.3, the following shall apply.

- a) The number and size of burners shall ensure that the visible flame length is a maximum of two-thirds of the radiant section height. For floor-fired heaters, the CO content at the bridge wall shall be a maximum of 40 ml/m³ (40 ppm, by volume) for gas-fired heaters, or 80 ml/m³ (80 ppm, by volume) for oil-fired heaters, at maximum design firing conditions.
- b) For horizontal opposed firing, the minimum visible clearance between directly opposed firing flame tips shall be 1.2 m (4 ft).


12.6.6.2 Shape

Flame shape should be uniform, centered on the burner axis and with length and width within specified requirements. Flame is the visually observable element of the combustion process. Flame dimensions should be recorded by visual observation and referenced off known test heater dimensions. The purchaser should specify desired dimensions as well as if there are minimum requirements. For example, both upper and lower limits for flame dimensions should be specified. If CO probing is required as a secondary method of verifying flame dimensions, the CO level should be determined ahead of time. It is generally considered that 99.99 % of the combustion reactions are complete at a CO isosurface of 2000 ppmvd. Also, the CO recorded should be averaged over a time period as CO fluctuates greatly as the measurement is being made in a turbulent environment.

The flame size (diameter or cross section and length), shape and intensity (color, luminosity and transparency) should be recorded for each test point. The test furnace dimensions (length, width and height) should be recorded.


Flame definition by CO probing

Probe is outside the flame and CO reading is "0", or
at least less than 40ppmv



Flame definition by CO probing


Probe enter the external layer of the flame and CO level raises up to 1000ppmv.



Flame definition by CO probing

The probe penetrates deeper and finally capture the main flame. CO increases to 2000ppmv and this is the boundary level where we generally consider 99.99% of the combustion reactions have completed.

2000ppmv threshold is a “suggested” value by API535 and there is full freedom for some user to specify any lower levels of CO threshold to give more margin to the design.



H2 flames do not produce CO ... so?

Industry and API already start discussing on how to define the H2 flame.

Possible solutions may be:

- O2 probing
- Heat Flux probing
- Validated CFD
- Etc

Why H2 fuel is so special?


	Natural Gas	Typical Refinery Gas	Hydrogen
Adiabatic Flame Temp * (°C)	1700	1750	1885
Laminar Flame Speed (cm/sec)	40	~80	312
volume based LHV (kcal/m3)	7475	9967	2438

*AFT calculated with the same amount of excess air per each fuel

- H2 fuel pressure is higher than HC fuels at a given heat release
- SAR (Stoichiometric Air Requirement) of H2 is lower than any other HC fuel
- Lower fluegas mass flowrate (partial duty swap between Convection and Radiant Sections)
- H2 flames are more compact (higher peak HF, higher NOx and HF profile moves down)
- Under certain conditions, H2 flames are less visible by human eyes

What does H2 rich fuel mean? H2 concentration curve (H2/NG mixture)

- Non-linearity between vol% and wt%
- 80vol% = 33wt% → 90%vol = 50wt%
- Most of the challenges and differences between hydrocarbon firing and H2 firing start showing-up above 90vol% (50wt%)



How H₂ flame looks like




Na₂CO₃ injection



NO_x emission with H₂ fuel

Burners for Fired Heaters in General Refinery Services

API RECOMMENDED PRACTICE 535
THIRD EDITION, MAY 2014




NOTE Figures are used for illustrative purposes and not to be used for verification or corrections. This figure is a generic curve and not applicable to individual low NO_x burner designs.

Figure 10—Effect of Hydrogen Content of Fuel Gas on NO_x Emission

NO_x emission with H₂ fuel

Burners for Fired Heaters in General Refinery Services

API RECOMMENDED PRACTICE 535
THIRD EDITION, MAY 2014




NOTE Figures are used for illustrative purposes and not to be used for verification or corrections. This figure is a generic curve and not applicable to individual low NO_x burner designs.


Figure 10—Effect of Hydrogen Content of Fuel Gas on NO_x Emission

How to properly compare (and report) NO_x emissions for HC and H₂ firing

	Wet flue gas		'Dry' flue gas correcting for water produced by combustion at 3 vol% O ₂	
	CH ₄ firing	H ₂ firing	CH ₄ firing	H ₂ firing
CO ₂ (vol%)	8.1	0.0	8.4	0.0
O ₂ (vol%)	2.9	2.8	3.0	3.0
N ₂ (vol%)	71.6	66.6	74.1	70.5
H ₂ O (vol%)	16.5	29.7	13.6	25.6
Ar (vol%)	0.9	0.8	0.9	0.8
Flue gas volume (Nm ³ / MJ _{th})	0.3422	0.3078	0.3307	0.2907
NO _x load (ton/ y)	10.0	10.0	10.0	10.0
NO _x conc. (mg/ Nm ³)	46.3	51.5	47.9	54.6
NO _x emission (gr/ MWh)	57.1	57.1	57.1	57.1




Fuel transition and safeguarding



Ref: John Zink Hamworthy Combustion Handbook

Effect of higher volume flow vs less resistance on overall Pressure drop




Exercise 1

Retrofit to Ultra Low NOx burner technology


Exercise 1: Expected (calculated) vertical Radiant Heat Flux Profile

It assumes same burner type, but
we need ULNB to keep NOx low
in H2 firing

FURDES model: RFG firing




FURDES model: pure H2 firing




Exercise 1: Burner retrofit to Ultra Low NOx technology

Old burner (Conventional Burner)







New burner (Ultra Low NOx Burner)





Exercise 1: Burner retrofit to Ultra Low NO_x technology

HEAT FLUX AT TUBES

Back View




Total Surface Heat




Exercise 2

Retrofit of a Natural draft VC heater to H₂ firing


Exercise 2: Furnace and burner layout




CURRENT
CONFIGURATION




Exercise 2: Flame interaction




Burner spacing too small – flames interact merging on top.



Burners spacing sufficient only to avoid flame interaction but not to allow fluegas recirculation



Proper burner spacing for ULNB's. No flame interaction and sufficient space for fluegas recirculation



Exercise 2: The importance of proper burner spacing




Flames are too close, and the circle diameter is too small flames interact merging into a big single flame




Candle flames are properly spaced with right Circle diameter. The flames are slightly curved to the centre.

Exercise 2: New burner layout

CURRENT
CONFIGURATION



10 FD BURNERS
smaller BCD




Exercise 2: Flame length calculation

API560 requirement: flame length to not exceed $\frac{2}{3}$ of the firebox height

TOT firing duty			56		MW		191.1		MMBTU/h	
#Burners	Flame length [mt]					Max firing				
	H2 firing		HC firing			duty				
	ND	FD	ND	FD		MW per Burner				
16	8.19	5.04	9.10	5.60		3.50	MW			
15	8.74	5.38	9.71	5.97		3.73	MW			
14	9.36	5.76	10.40	6.40		4.00	MW			
13	10.08	6.20	11.20	6.89		4.31	MW			
12	10.92*	6.72	12.13*	7.47		4.67	MW			
11	11.91*	7.33	13.24*	8.15		5.09	MW			
10	13.10*	8.06	14.56*	8.96		5.60	MW			
9	14.56*	8.96	16.18*	9.96		6.22	MW			
8	16.38*	10.08	18.20*	11.20		7.00	MW			
7	18.72*	11.52	20.80*	12.80		8.00	MW			
6	21.84*	13.44	24.27*	14.93		9.33	MW			

* firing duty not suitable for Natural Draft burner design (too high)



Questions and Answers

Q&A

